

## Natalie Barletta

---

**From:** J. Howard Pfrommer, P.E. <hpfrommer@nlja.com>  
**Sent:** Tuesday, May 4, 2021 4:38 PM  
**To:** Ricardo Ceballos  
**Cc:** Rick Hurlburt; Daniel Wolff; Luigi DiMonaco; bp@pellegrinolawfirm.com; Matthew J. Davis; Mark Austin; Natalie Barletta; Dennis J Faga; Michael B Tyre  
**Subject:** RE: 2021-061 385 New Road - QU Modular Labs (Special Permit & Site Plan 00-903)  
**Attachments:** 05-04-2021 BVH Plumbing Plan.pdf; Sanitary Sewer Design Summary Form\_EXECUTED.pdf

Hi Ricardo.

The plumbing plan and executed *Sanitary Sewer Design Summary Form* are attached.

As you know, we are working on the CTDEEP permit.

Thank you.

---

**From:** Ricardo Ceballos <rceballos@gnhwpc.com>  
**Sent:** Monday, May 3, 2021 12:29 PM  
**To:** bp@pellegrinolawfirm.com; J. Howard Pfrommer, P.E. <hpfrommer@nlja.com>; Matthew J. Davis <mdavis@Hamden.com>; Mark Austin <maustin@hamden.com>; Natalie Barletta <nbarletta@Hamden.com>  
**Cc:** Rick Hurlburt <RHurlburt@gnhwpc.com>; Daniel Wolff <DWolff@gnhwpc.com>; Luigi DiMonaco <LDimonaco@gnhwpc.com>  
**Subject:** 2021-061 385 New Road - QU Modular Labs (Special Permit & Site Plan 00-903)

CAUTION: This email originated from outside your organization. Exercise caution when opening attachments or clicking links, especially from unknown senders.

Please reference GNHWPCA Ref.# 2021-061 on any future correspondence including emails for the above referenced project.

The enclosed documents provide the guidelines and forms required to complete the process of obtaining plan approvals and connections permits.

The Authority has the following comments on the plans reviewed:

- Sewer connection permit is required prior to the start of construction of sewer related infrastructure. Sewer connection fee will be based on new 1.5" water service to the proposed modular buildings if no separate meter is available.
- Please provide a copy of the plumbing plans for our review and records.
- The proposed industrial discharge requires the owner to apply for a DEEP miscellaneous discharge permit.
- Wastewater generation rates must be provided. Please use the average flow rate table in the GNHWPCA criteria manual to determine the projected wastewater flow from the proposed facility.
- Attached is the sanitary sewer design summary form that must be filled out and stamped by a P.E.
- There are no additional comments on the plans submitted.

Sewer connection permit may be pulled from 8-11 am, Monday through Friday at 345 East Shore Parkway, New Haven 06512. You can call Dan Wolff, GNHWPCA Inspector, at 203-466-5280 x243 if you have any questions regarding the permit.

Please contact me if you have any questions.

**Ricardo Ceballos, P.E.**

**Greater New Haven Water Pollution Control Authority**

260 East Street

New Haven, CT 06511

p: 203.466.4122

f: 203.772.2027

[rceballos@gnhwPCA.com](mailto:rceballos@gnhwPCA.com)

 Please consider the environment before printing this email.